



ANSCHLUSSSCHEMA - TE700 ERDUNGSSICHERHEITSMONITOR



INSTALLING TE700 GROUNDING MONITOR



Connect ground cords 9TE700E01 and 9TE700E05 (use binder screw 9TE700E06 for fixation) to table mat and EPB earth bonding point.

When using 2 table mats use connecting coil cord 910900 000051 together with binder screws 9TE700E06 for fixed connection of both mats.

